

Emission Test Certificate

Thursday, 17th May 2018

Supplier: Gerflor Australia Pty Ltd (17 Cato St, Hawthorn East, VIC, 3123, Australia)

Sample Description: Texline HQR

Date Tested: April 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116:2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs exposure):

<p>Green Building Council of Australia Green Star Design and As Built v1.1 13.1.2B & 13.2 Green Star Interiors V1.1 - 12.1.2B</p>	<p>Texline HQR</p>
<p>Total Volatile Organic Compound Emission Rate limit <0.5 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.099mg/m²/hr</p>
<p>Formaldehyde Emission Rate limit <0.1 mg/m²/hr</p>	<p>Formaldehyde Emission Rate: 0.026 mg/m²/hr</p>
<p><i>We hereby certify Texline HQR is well below the VOC Emission limits specified by Green Star Design and As Built, Green Star Interiors, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B Eng. (Chem.)
Consultant

CV180470a