



Infrastructure Technologies

Gate 5, 2 Normanby Road Clayton VIC 3168, Australia

Telephone: 61 3 9545 2777 Web: <http://www.csiro.au>

Registered Testing Authority - CSIRO

15 December 2016

Our Ref. EN13 / 415 03/0212

TEST REPORT No. 7814

Requested by: Gerflor Australasia P/L
17 Cato St
Hawthorn East
VIC 3123

on (date): 5 December 2016

Manufacturer: Gerflor, Tarare France

Product Desc.: Texline Pro Commercial flooring - Heterogeneous Acoustic.
Protected by an exceptionally tough and resilient scratch resistant 0.5mm commercial quality wear layer.
Polyurethane (PUR) surface treatment facilitates excellent stain resistance and easy maintenance. Suitable for high traffic areas.
GreenTag Level A certified

Sampling details:

Where: Delivered

Date: 7 December 2016

By whom: Courier

How (methods): N/A

The results reported relate only to the sample(s) tested and the information received. No responsibility is taken for the accuracy of the sampling unless it is done under our own supervision. CSIRO cannot accept responsibility for deviations in the manufactured quality and performance of the product. While CSIRO takes care in preparing the reports it provides to clients, it does not warrant that the information in this particular report will be free of errors or omissions or that it will be suitable for the client's purposes. CSIRO will not be responsible for the results of any actions taken by the client or any other person on the basis of the information contained in the report or any opinions expressed in it. The reproduction of this test report is only authorised in the form of a complete photographic facsimile. Our written approval is necessary for any partial reproduction.

This test report consists of 3 pages

SUMMARY OF SLIP RESISTANCE TESTS PERFORMED:

		Result	Class
AS 4586:2013	Slip resistance classification of new pedestrian surface materials Appendix A: WET Pendulum (Slider 96):		
	Mean SRV:	28	P2

In order to interpret the classifications, please refer to Standards Australia Handbook 198, An Introductory Guide to the Slip Resistance of Pedestrian Surface Materials, which recommends minimum classifications for a wide variety of locations.

It is important to realise that test results obtained on unused factory-fresh samples may not be directly applicable in service, where proprietary surface coatings, contamination, wear and subsequent cleaning all influence the behaviour of the pedestrian surface.



REPORT NO: 7814 Page 2 of 3
 ISSUE DATE: 15 December 2016
 MANUFACTURER: Gerflor, Tarare France
 PRODUCT DESC: Texline Pro Commercial flooring - Heterogeneous Acoustic.
 Protected by an exceptionally tough and resilient scratch resistant 0.5mm commercial quality wear layer.
 Polyurethane (PUR) surface treatment facilitates excellent stain resistance and easy maintenance. Suitable for high traffic areas.
 GreenTag Level A certified

SLIP RESISTANCE CLASSIFICATION OF NEW PEDESTRIAN SURFACE MATERIALS

WET PENDULUM TEST METHOD

TEST CARRIED OUT IN ACCORDANCE WITH AS 4586:2013 (Appendix A)

Test Date: 14 December 2016

RESULTS: Location: Slip Resistance Laboratory Slider used: 96
 Sample: Unfixed Conditioned with grade P400 paper, dry
 Cleaning: Deionized water and Imperial Lapping Film Grade 3MIC, wet
 Temperature: 22.4°C
 Pendulum Friction Tester: Stanley (S/N: 0312, calibrated 03/06/2014)
 Test conducted by: Khanh Ho

	Specimen					
	1	2	3	4	5	
Last 3 swings (BPN)	33	28	29	28	29	
	31	26	27	27	27	
	29	26	26	26	26	
Averages	31	27	27	27	27	Mean SRV : 28

CLASS :

P2



Infrastructure Technologies

Gate 5, 2 Normanby Road Clayton VIC 3168, Australia

Telephone: 61 3 9545 2777 Web: <http://www.csiro.au>

REPORT NO: 7814 Page 3 of 3
ISSUE DATE: 15 December 2016
MANUFACTURER: Gerflor, Tarare France
PRODUCT DESC: Texline Pro Commercial flooring - Heterogeneous Acoustic.
Protected by an exceptionally tough and resilient scratch resistant 0.5mm commercial quality wear layer.
Polyurethane (PUR) surface treatment facilitates excellent stain resistance and easy maintenance. Suitable for high traffic areas.
GreenTag Level A certified

Date and Place 15 December 2016, Clayton, Vic

Name, Title and Digital Signature:

A digital signature in black ink, appearing to read 'Khanh Ho', is overlaid on a circular watermark of the CSIRO logo.

KHANH HO
Technical Officer
Tel: 61 3 95452777
Email: Khanh.Ho@csiro.au
