

# Emission Test Certificate

Friday, December 07, 2012

Supplier: Gerflor Australasia Pty Ltd (17 Cato St, Hawthorn East, VIC, 3123)

Sample Description: GTI TILE

Date Tested: December 2012


Test Method: ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V2/V3 IEQ-13</b> <b>Green Star Office Interiors V1.1 IEQ-11</b>	<b>GTI Tile</b>
Total Volatile Organic Compound emission rate <0.5 mg/m <sup>2</sup> /hr (24 Hours)	Total Volatile Organic Compound emission rate <0.018 mg/m <sup>2</sup> /hr (24 Hours)



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Travis Hale  
BSc  
Consultant

CV121118