

# Emission Test Certificate

Thursday, May 10<sup>th</sup>, 2012

Supplier: Gerflor (17 Cato St, Hawthorn East, VIC 3123)

Sample Description: Taraflex Sport M Evolution (7 mm)

Date Tested: April 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p><b>Green Building Council of Australia Green Star Office Design IEQ-13</b></p>	<p><b>Taraflex Sport M Evolution (7mm)</b></p>
<p>Total Volatile Organic Compound Emission Rate limit &lt;math&gt;&lt;0.5\text{mg}/\text{m}^2/\text{hr}&lt;/math&gt;</p>	<p>Total Volatile Organic Compound Emission Rate: &lt;math&gt;&lt;0.033\text{mg}/\text{m}^2/\text{hr}&lt;/math&gt; (24 hours)</p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Anne Saletti  
BNanotech/BSc(Hons)  
Consultant

CV120415