

Emission Test Certificate

Thursday, May 10th, 2012

Supplier: Gerflor (17 Cato St, Hawthorn East, VIC 3123)

Sample Description: Taraflex Sport M Performance (9 mm)

Date Tested: April 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p>Green Building Council of Australia Green Star Office Design IEQ-13</p>	<p>Taraflex Sport M Performance (9 mm)</p>
<p>Total Volatile Organic Compound Emission Rate limit <math><0.5\text{mg}/\text{m}^2/\text{hr}</math></p>	<p>Total Volatile Organic Compound Emission Rate: <math><0.005\text{mg}/\text{m}^2/\text{hr}</math> (24 hours)</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Anne Saletti
BNanotech/BSc(Hons)
Consultant

CV120415