

**ATTAR TEST REPORT NUMBER: 15/9604.1**

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.
Accredited for compliance with ISO/IEC 17025.
Accreditation Number: 2735

18 November 2015

Total Pages: 2**WET PENDULUM SLIP RESISTANCE**

Job No: M15/9604

Prepared for:	Gerflor Australasia Pty Ltd. 17 Cato Street HAWTHORN EAST VIC 3123					
Attention:	Gill Coleman					
Test Site:	ATTAR, Unit 1, 64 Bridge Road, Keysborough.					
Test Date:	14 August 2014					
Test Specimens, Size & Quantity:	Virtuo 55 Classic vinyl plank, 184x121.9 cm, 5 off supplied.					
Sampling & Direction of Testing:	Sampling conducted by client. Test direction parallel with profiled pattern. Refer to Figure 1.					
Test Personnel:	Douglas Lehne					
Preparation:	Washed with water and pH neutral detergent, rinsed with water, then dried.					
Fixed/Unfixed:	Unfixed.					
Air Temperature:	22°C					
Test Equipment:	Munro Stanley Skid Resistance Tester (Pendulum) Serial Number 0320, Calibrated 16/10/2013.					
Test Standard:	AS 4586: 2013 Slip resistance classification of new pedestrian surface materials – Appendix A.					
Slider Rubber:	Slider 96 Batch No. #54 prepared on P400 & 3µm lapping film.					
Classification Criteria:	Refer to Classification Criteria, attached as Appendix 1.					
British Pendulum Number	Specimen Number					SRV
	1	2	3	4	5	
	46	40	41	41	40	
Classification:	P3					

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance procedures and wear on their slip-resistance be checked.

NOTE: Any specimens supplied will be disposed of in two (2) months time, unless otherwise instructed.

ATTAR

Douglas Lehne
Floor Slip Tester
Approved Signatory

This report may not be reproduced except in its entirety.

Page 1 of 2

ATTAR TEST REPORT NUMBER: 15/9604.1

18 November 2015

Total Pages: 2



Figure 1: Virtuo 55 Classic vinyl plank. Arrow indicates direction of test.